



KLADOW WATERWORKS

The Kladow waterworks operates in cooperation with the Tegel waterworks.

CHRONICLE

1932

Construction of a pumping station to improve the water supply to Gatow and Kladow.

1937

Expansion of the pumping station into a waterworks.

1973

Commissioning of the newly built waterworks

TECHNICAL DATA

Max. capacity:

30,000 m³/day

Water winning:

14 vertical wells, 34 to 93 m deep, with underwater motor pumps. Deliveries of the pumps between 80 and 250 m³ per hour.

Water treatment:

Two square aeration chambers with 200 nozzles for aeration of the raw water, one filter hall with six open double filters. The filter surface area totals 414 m², the maximum filtration rate is 6.0 m per hour.

Water delivery:

One diesel centrifugal pump and three electric centrifugal pumps with deliveries between 500 and 2,000 m³ per hour and a pressure of 7.0 bar.



Postal address
Berliner Wasserbetriebe
10864 Berlin

Contact
Tel.: 0800.292 75 87
Fax: 030 8644 - 2810
E-Mail: pr@bwb.de
Internet: www.bwb.de